

TYPE EXAMINATION CERTIFICATE

Issued by Liftinstituut B.V.

- Certificate no. : NL14-400-1002-048-12 Revision no.: 4
- Description of the product : Complete Lift Control Panel for electric lifts
- Trademark, type : Arkel, ARCODE Lift Control Panel
- Name and address of the manufacturer : Arkel Elektrik Elektronik San. ve Tic. As.
Serifali Mah. Turker Cad. No:51 34775
Umraniye, Istanbul, Turkey
- Name and address of the certificate holder : Arkel Elektrik - Elektronik Tic. Ltd. Sti.
Bostanci Yolu Cad. Sehit Sok. No:36
Yukari Dudullu, Istanbul, Turkey
- Certificate issued on the following requirements : Lifts Directive 2014/33/EU
- Certificate based on the following standards : Parts of EN 81-20:2014 and EN 81-50:2014
- Test laboratory : None
- Date and number of the laboratory report : None
- Date of type-examination : March – September 2013, Rev.1; November 7, 2014, Rev.2; August 2015, Rev.3; July 2016; Rev.4; August 31, 2016
- Additional document with this certificate : Annex belonging to the type-examination certificate no.: NL14-400-1002-048-12 rev.4
- Additional remarks : The printed circuit boards are not subjected to the laboratory tests according to clause 5.6 of EN 81-50
Furthermore see chapter 5 of the report belonging to this type examination certificate.
- Conclusion : The ARCODE Lift Control Panel meets the requirements referred to in this certificate taking into account any additional remarks mentioned above.

Amsterdam
Date of issue : 31-08-2016
Valid until : 07-07-2021

ing. J.L. van Vliet
Managing Director

Certification decision by